

Routine Test Report

Date: 28.09.05



Customer:		RATED VALUE:	
AIR LIQUIDE AGS GmbH Site manager Mr. Josef Gvora Job Site of AIR Separation Unit No. 9 SK-04454 Kosice		type designation	AHA12-50-09
		Number of this standard	IEC 62271-200 / 2003
		Number of this standard	IEC 60298 / 1994
		voltage - kV	12
		withst. impulse volt. - kV	75
		withst. power frequency volt. kV	28
		frequency - Hz	50
		operating current outgoing - A	1250
		short-time withstand c. - kA	50
		short circuit duration - sec.	3
		Internal arc classification	IEC 60298
		operating current busbar - A	4000
		operating/installation instr.	531681/531686
		-	=L021
		Purchase order no.	009781
			.
			.
Equipment:			
Customer no.	=L021		
Production no.	TC436574-1		
Type designation	AHA12-50-09		
Year of production	2005		
Purchase order:			
US Steel Kosice			
Purchase order no. 9781			
Customer ref. 3234-4500066080			

Tests passed acc. to IEC:

Power frequency high voltage test on main circuit (IEC 60298/7.1)
Dielectric test on auxiliary and control circuits (IEC 60298/7.2)
Mechanical operation test. (IEC 60298/7.102))
Test of the auxiliary electrical devices. (IEC 60298/7.105)
Verification of correct wiring. (EN 60298/7.106)
Test of the capacitive voltage indication system (IEC 60243-5)