

VNUTRINA JED. FF060BY1B  
INSIDE UNIT FF060BY1B  
PRKON 140 W, 240 V, 50 Hz  
INPUT POWER 140 W, 240V, 50Hz  
OVLAD. - VLASTNÉ INFRA  
HANDL. - INFRA CONTROL SYSTEM

WOKKASJA, EENOTKA RX560BMB  
OUTSIDE UNIT RX560BMB  
CHILL. VPKON 0.90-5.80-6.00 kW  
COLING. VPKON 0.90-5.80-6.00 kW  
PRKON - CHAEOINE 0.45-2.07-2.15 kW  
COLING INPUT POWER 0.45-2.07-2.15 kW  
VYKIR. VPKON 0.90-7.00-8.00 kW  
HEATING POWER 0.90-7.00-8.00 kW  
PRKON - KGRFENE 0.45-2.49-2.92 kW  
HEATING INPUT POWER 0.45-2.49-2.92 kW  
O.W.L.D. - VLASTINE AUTOMA.  
HANDL. - CUSTOM CONTROL SYSTEM

WOKRASA, EDMONTA RX500BMB  
OUTSIDE UNIT RX500BWM  
CHLD. PWRK 0.90-5.80-6.00 kW  
COLNG. PWRK 0.90-5.80-6.00 kW  
PRKCN - CHL ADENIE 0.45-2.07-2.15 kW  
COLING INPUT POWER 0.45-2.07-2.15 kW  
VTRKR. WPKN 0.90-7.00-8.00 kW  
HEATING POWER 0.90-7.00-8.00 kW  
PRKCN - KURJENIE 0.45-2.49-2.92 kW  
HEATING INPUT POWER 0.45-2.49-2.92 kW  
ON/AD - VLASTNE AUTOM.  
HANDL. - CUSTOM CONTROL SYSTEM

VNUTRORNA JED. FF0608BY1B  
 INSIDE UNIT FF0608BY1B  
 PRKON 140 W, 240 V, 50 Hz  
 INPUT POWER 140 W, 240V, 50Hz  
 OVLAD.- VLASTNÉ INFRA  
 HANDL - INFRA CONTROL SYSTEM

Ventilátor – TD 250 /100 (90–140 m<sup>3</sup>/h)  
Fom – TD 250 /100 (90 – 140 m<sup>3</sup>/h)  
26–40 W, 220–240 V, 50 Hz, 0,18–0,26 A  
OM.AD.-KLIMATIZAČ. JEDNOTKA  
HANDL – AIRCONDITIONING UNIT



# FREE-GATE FOR CONSTRUCTION

Pa 15.04.05

HS HSV s.r.o. KOŠICE  
Technický úsek

$\pm 0,000 = 225,150 \text{ m.n.m}$

±0,000=225,150m.n.m  
SPRACOVANÉ POD ZÁKAZKOVÝM ČÍSLOM:158/2004/SO/

							
		<b>AIR LIQUIDE</b> <small>TM</small>					
Air Liquide ACS GmbH							
Replaces:	79						
Replaced by:	79						
Title: VELIN/CONTROL BUILDING REL/SECTION VZDUCHOTECHNIKA/VENTILATION		Date : JANUARY 2005		Name : INC:BAWK <i>h</i>		Checked: INC:RDEK	
Job code: K 70101		Reference: ASU No.9 KOSICE		History file:		Rev. 0	
Scale 1:50		Original format DIN A2					
Sheet --- of --- Sheets		Drawing No.: 792.87394		Rev. 0			