

TO: AUTHORIZED INSPECTOR
HSB CT.

DATE: 28-JAN-05

SUBJECT: TRANSMITTAL OF ASME SUBMITTAL CALCULATIONS FOR A.I. ACCEPTANCE


GENTLEMEN:

ATTACHED ARE ASME PRESSURE VESSEL CODE CALCULATIONS ACCORDING TO THE 2001 EDITION, 2003 ADDENDA OF SECTION VIII, DIVISION 1, OF THE ASME CODE. THE CALCULATIONS SUPPORT THE DESIGN OF THE FOLLOWING VESSEL.

ASSEMBLY DRAWING -----	SALES ORDER -----	CUSTOMER -----
15770A REV A	509.8	AL-DEUTSCHLAND

LOADINGS LISTED IN UG-22 HAVE BEEN CONSIDERED IN THE DESIGN OF THE VESSEL AND THE CUSTOMER ADVISED OF THE MAXIMUM LOADS THAT MAY BE APPLIED. YOUR ACCEPTANCE OF THESE CALCULATIONS AND THE VESSEL DESIGN AS MEETING THE MINIMUM REQUIREMENTS OF THE ASME CODE, SECTION VIII, DIV. 1, IS RESPECTFULLY REQUESTED. PLEASE ACKNOWLEDGE YOUR ACCEPTANCE BY SIGNING AND DATING THIS FORM IN THE SPACE PROVIDED.


BEST REGARDS,



PRODUCT ENGINEERING
CHART HEAT EXCHANGERS

A.I. ACCEPTANCE

I HAVE REVIEWED THE CALCULATIONS AND THE ABOVE LISTED DRAWING. IN MY OPINION THIS DESIGN DOES MEET THE MINIMUM REQUIREMENTS OF THE ASME CODE SECTION VIII, DIV. 1



----- 20 4-05

AUTHORIZED INSPECTOR	DATE
HSB CT.	

SUBJECT: ASME SUBMITTAL CALCULATIONS PER THE 2001 EDITION,
2003 ADDENDA OF SECTION VIII, DIVISION 1.CUSTOMER: AL-DEUTSCHLAND
SALES ORDER: 509.8
ASSEMBLY DRAWING: 15770A REV A
ITEM: W20000

DESIGN BASIS:

- CODE JURISDICTION ENDS AT FIRST NOZZLE CIRCUMFERENTIAL WELD JOINT.
- MAXIMUM DESIGN TEMPERATURE= 150. DEGREES F
- CORROSION ALLOWANCE: NONE
- ASME CODE REQUIRED RADIOGRAPHY:

NONE.

FIN DESIGN:

THE MAXIMUM ALLOWABLE DESIGN PRESSURE OF THE FINS USED IN THIS HEAT EXCHANGER MEET OR EXCEED THE STREAM DESIGN PRESSURE. THE RATINGS WERE CALCULATED PER PARAGRAPH U-2(G). THE PROPRIETARY CALCULATION METHOD WAS APPROVED BY CHART AND REVIEWED AND ACCEPTED BY HSB CT.

PIPING DESIGN:

CONNECTION	HEADER			NOZZLE			DESIGN PRESSURE P.S.I.G.
	O.D. X	WALL X	MATERIAL	O.D. X	WALL X	MATERIAL	
	IN. X	IN.		IN. X	IN.		
A IN	16.000	0.375	SB-209-5083	12.750	0.375	SB-241-5083	149.
A OUT	10.000	0.250	SB-209-5083	8.625	0.322	SB-241-5083	149.
B IN	13.000	1.000	SB-209-5083	6.625	0.432	SB-241-5083	914.
B OUT	10.750	0.750	SB-209-5083	6.625	0.432	SB-241-5083	914.
C IN	10.750	0.750	SB-209-5083	4.500	0.237	SB-241-5083	914.
C OUT	5.563	0.375	SB-209-5083	3.500	0.216	SB-241-5083	914.
D IN	6.625	0.375	SB-209-5083	2.375	0.154	SB-241-5083	580.
D OUT	10.750	0.500	SB-209-5083	4.500	0.237	SB-241-5083	580.
E IN	2.875	0.203	SB-241-5083	1.900	0.145	SB-241-5083	435.
E OUT	10.750	0.375	SB-209-5083	3.500	0.216	SB-241-5083	435.
F IN	10.750	0.250	SB-209-5083	10.750	0.365	SB-241-5083	40.
F OUT	14.000	0.250	SB-209-5083	12.750	0.375	SB-241-5083	40.
G IN	14.000	0.250	SB-209-5083	14.000	0.250	SB-209-5083	40.
G OUT	18.000	0.250	SB-209-5083	14.000	0.250	SB-209-5083	40.

NOTE: PER UG-36(C)(3)(a), REINFORCEMENT CALCULATIONS ARE NOT
MADE FOR 2" NPS NOZZLES OR SMALLER.THE C IN HEADER NOZZLE JOINT REQUIRES A 0.250 IN FILLET WELD.
THE C OUT HEADER NOZZLE JOINT REQUIRES A 0.375 IN FILLET WELD.NOTE: A, F & G STREAM DESIGN PRESSURES INCREASED BY A FACTOR OF
1.50/1.10 TO ACCOUNT FOR ELEVATED PNEUMATIC TEST PRESSURE.

CALCULATIONS SUBMITTED BY:

PRODUCT ENGINEERING
CHART HEAT EXCHANGERS

CHECKED BY:

PRODUCT ENGINEERING
CHART HEAT EXCHANGERS

TÜV Süddeutschland Bau und Betrieb GmbH

Noting to Pressure

Equipment Directive 97/23/EC

-Testing Laboratory-

MAR 29 2005



HEADER OPENING AND REINFORCING CALCULATION
PER ASME SECTION VIII, DIV 1., PAR UG-36,UG-40,AND UG-42
(NOZZLE ABUTTS THE HEADER BODY, REF FIG UW-16.1(a))

STREAM	A IN
DESIGN PRESSURE (P)	149. PSIG
HEADER SIZE (O.D.)	16.000 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (T)	0.375 INCHES
INSIDE RADIUS (R)	7.625 INCHES
MINIMUM HEADER THICKNESS (UG-27)	
TR=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.100 INCHES
NOZZLE SIZE (O.D.)	12.750 INCHES
MATERIAL	SB-241-5083-0
ALLOWABLE STRESS (S)	10700. PSI
WALL THICKNESS (TN)	0.375 INCHES
INSIDE DIAMETER (D)	12.000 INCHES
INSIDE RADIUS (R)	6.000 INCHES
MINIMUM NOZZLE THICKNESS	
TRN=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.084 INCHES
HEADER/NOZZLE WELD JOINT	
MIN. WELD LEG =SMALLER OF (T), (TN) OR .25/.707	0.354 INCHES
ACTUAL WELD LEG (W)	0.375 INCHES

REINFORCEMENT CALCULATION UG-37

AVAILABLE AREA	
SHELL: LARGER OF: (NOTE 1)	E1=1.00
A1A $D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR) (1 - FR1)$	
A1B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR) (1 - FR1)$	3.295 IN2
NOZZLE: SMALLER OF:	
5(TN-TRN)(FR2)(T) OR	
A2 5(TN-TRN)(FR2)(TN)	0.512 IN2
ADDITIONAL AREA IF USED (RE-PAD OR INWARD NOZZLE)	
A3 $(DP - D - 2TN)TE(FR4)$ OR $2(TN)FR2 \cdot H$	0.000 IN2
WELD AREA	
A4 $W \cdot W \cdot (FR2)$	0.132 IN2
ATOT ATOT=A1+A2+A3+A4	3.938 IN2
REQUIRED AREA	
AREQ=D*TR*F+2*TN*TR*F(1-FR1) (F=1.0)	1.205 IN2

REINFORCEMENT CALCULATION APPENDIX (1-7a). (NOTE 2) Rn/R= 0.79

A1(1-7) = LARGER OF A1(1-7)A OR A1(1-7)B	
A1(1-7)A $.5 \cdot D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR) (1 - FR1)$	
A1(1-7)B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR) (1 - FR1)$	1.647 IN2
ATOT(1-7)=A1(1-7)+A2+A3+A4	2.291 IN2
AREQ(1-7)=(2/3) X AREQ	0.804 IN2

- (1) E1 NORMALLY EQUALS 1.0. WHEN THE NOZZLE PASSES THROUGH A CATEGORY A WELD JOINT E1 IS TAKEN FROM TABLE UW-12.
- (2) REFERENCE PAR. UG-36(B-1). THIS CALCULATION IS REQUIRED WHEN THE OPENING IS GREATER THAN HALF THE HEADER I.D. OR THE OPENING EXCEEDS 20 INCHES.
- (3) FR1=1.0 OR SN/SV FOR INSERTED NOZZLES.
FR2=SN/SV, FR3=(LESSER OF SN OR SP)/SV, FR4=SP/SV.
- (4) TR & TRN ARE BASED ON SEAMLESS MATERIAL PER DEFINITIONS IN UG-37.

Zur Handzeichnung zugehörig.
Befertigt ist die Handzeichnung.
Prüfvermerk vom / Review date:

MAR 29 2005

[Handwritten signature]

HEADER OPENING AND REINFORCING CALCULATION
PER ASME SECTION VIII, DIV 1., PAR UG-36, UG-40, AND UG-42
(NOZZLE ABUTTS THE HEADER BODY, REF FIG UW-16.1(a))

STREAM	A OUT
DESIGN PRESSURE (P)	149. PSIG
HEADER SIZE (O.D.)	10.000 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (T)	0.250 INCHES
INSIDE RADIUS (R)	4.750 INCHES
MINIMUM HEADER THICKNESS (UG-27)	
TR=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.063 INCHES
NOZZLE SIZE (O.D.)	8.625 INCHES
MATERIAL	SB-241-5083-0
ALLOWABLE STRESS (S)	10700. PSI
WALL THICKNESS (TN)	0.322 INCHES
INSIDE DIAMETER (D)	7.981 INCHES
INSIDE RADIUS (R)	3.990 INCHES
MINIMUM NOZZLE THICKNESS	
TRN=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.056 INCHES
HEADER/NOZZLE WELD JOINT	
MIN. WELD LEG =SMALLER OF (T), (TN) OR .25/.707	0.250 INCHES
ACTUAL WELD LEG (W)	0.322 INCHES

REINFORCEMENT CALCULATION UG-37

AVAILABLE AREA	
SHELL: LARGER OF: (NOTE 1)	E1=1.00
A1A $D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	1.496 IN2
NOZZLE: SMALLER OF:	
5(TN - TRN)(FR2)(T) OR	
A2 5(TN - TRN)(FR2)(TN)	0.312 IN2
ADDITIONAL AREA IF USED (RE-PAD OR INWARD NOZZLE)	
A3 $(DP - D - 2TN)TE(FR4)$ OR $2(TN)FR2 \cdot H$	0.000 IN2
WELD AREA	
A4 $W \cdot W \cdot (FR2)$	0.097 IN2
ATOT $ATOT = A1 + A2 + A3 + A4$	1.905 IN2
REQUIRED AREA	
AREQ $= D \cdot TR \cdot F + 2 \cdot TN \cdot TR \cdot F(1 - FR1)$ (F=1.0)	0.499 IN2

REINFORCEMENT CALCULATION APPENDIX (1-7a). (NOTE 2) $R_n/R = 0.84$

A1(1-7) = LARGER OF A1(1-7)A OR A1(1-7)B	
A1(1-7)A $.5 \cdot D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1(1-7)B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	0.748 IN2
ATOT(1-7) = A1(1-7) + A2 + A3 + A4	1.157 IN2
AREQ(1-7) = (2/3) X AREQ	0.333 IN2

- (1) E1 NORMALLY EQUALS 1.0. WHEN THE NOZZLE PASSES THROUGH A CATEGORY A WELD JOINT E1 IS TAKEN FROM TABLE UW-12.
- (2) REFERENCE PAR. UG-36(B-1). THIS CALCULATION IS REQUIRED WHEN THE OPENING IS GREATER THAN HALF THE HEADER I.D. OR THE OPENING EXCEEDS 20 INCHES.
- (3) FR1=1.0 OR SN/SV FOR INSERTED NOZZLES.
FR2=SN/SV, FR3=(LESSER OF SN OR SP)/SV, FR4=SP/SV.
- (4) TR & TRN ARE BASED ON SEAMLESS MATERIAL PER DEFINITIONS IN UG-37.

Prepared by: [Signature]
Checked by: [Signature]
Reviewed date: [Signature]

MAR 29 2005

[Signature]

HEADER OPENING AND REINFORCING CALCULATION
PER ASME SECTION VIII, DIV 1., PAR UG-36, UG-40, AND UG-42
(NOZZLE ABUTTS THE HEADER BODY, REF FIG UW-16.1(a))

STREAM	B IN
DESIGN PRESSURE (P)	914. PSIG
HEADER SIZE (O.D.)	13.000 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (T)	1.000 INCHES
INSIDE RADIUS (R)	5.500 INCHES
MINIMUM HEADER THICKNESS (UG-27)	
TR=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.463 INCHES
NOZZLE SIZE (O.D.)	6.625 INCHES
MATERIAL	SB-241-5083-0
ALLOWABLE STRESS (S)	10700. PSI
WALL THICKNESS (TN)	0.432 INCHES
INSIDE DIAMETER (D)	5.761 INCHES
INSIDE RADIUS (R)	2.881 INCHES
MINIMUM NOZZLE THICKNESS	
TRN=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.259 INCHES
HEADER/NOZZLE WELD JOINT	
MIN. WELD LEG =SMALLER OF (T), (TN) OR .25/.707	0.354 INCHES
ACTUAL WELD LEG (W)	0.432 INCHES

REINFORCEMENT CALCULATION UG-37

AVAILABLE AREA	
SHELL: LARGER OF: (NOTE 1)	E1=1.00
A1A $D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	3.092 IN2
NOZZLE: SMALLER OF:	
5(TN-TRN)(FR2)(T) OR	
A2 5(TN-TRN)(FR2)(TN)	0.350 IN2
ADDITIONAL AREA IF USED (RE-PAD OR INWARD NOZZLE)	
A3 (DP-D-2TN)TE(FR4) OR 2(TN)FR2*H	0.000 IN2
WELD AREA	
A4 W*W*(FR2)	0.175 IN2
ATOT ATOT=A1+A2+A3+A4	3.617 IN2
REQUIRED AREA	
AREQ=D*TR*F+2*TN*TR*F(1-FR1) (F=1.0)	2.669 IN2

REINFORCEMENT CALCULATION APPENDIX (1-7a). (NOTE 2) Rn/R= 0.52

A1(1-7) = LARGER OF A1(1-7)A OR A1(1-7)B	
A1(1-7)A $.5 \cdot D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1(1-7)B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	1.546 IN2
ATOT(1-7)=A1(1-7)+A2+A3+A4	2.071 IN2
AREQ(1-7)=(2/3) X AREQ	1.779 IN2

- (1) E1 NORMALLY EQUALS 1.0. WHEN THE NOZZLE PASSES THROUGH A CATEGORY A WELD JOINT E1 IS TAKEN FROM TABLE UW-12.
- (2) REFERENCE PAR. UG-36(B-1). THIS CALCULATION IS REQUIRED WHEN THE OPENING IS GREATER THAN HALF THE HEADER I.D. OR THE OPENING EXCEEDS 20 INCHES.
- (3) FR1=1.0 OR SN/SV FOR INSERTED NOZZLES.
FR2=SN/SV, FR3=(LESSER OF SN OR SP)/SV, FR4=SP/SV.
- (4) TR & TRN ARE BASED ON SEAMLESS MATERIAL PER DEFINITIONS IN UG-37..

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005

T.R.

HEADER OPENING AND REINFORCING CALCULATION
PER ASME SECTION VIII, DIV 1., PAR UG-36,UG-40,AND UG-42
(NOZZLE ABUTTS THE HEADER BODY, REF FIG UW-16.1(a))

STREAM	B OUT
DESIGN PRESSURE (P)	914. PSIG
HEADER SIZE (O.D.)	10.750 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (T)	0.750 INCHES
INSIDE RADIUS (R)	4.625 INCHES
MINIMUM HEADER THICKNESS (UG-27)	
TR=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.390 INCHES
NOZZLE SIZE (O.D.)	6.625 INCHES
MATERIAL	SB-241-5083-0
ALLOWABLE STRESS (S)	10700. PSI
WALL THICKNESS (TN)	0.432 INCHES
INSIDE DIAMETER (D)	5.761 INCHES
INSIDE RADIUS (R)	2.881 INCHES
MINIMUM NOZZLE THICKNESS	
TRN=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.259 INCHES
HEADER/NOZZLE WELD JOINT	
MIN. WELD LEG =SMALLER OF (T), (TN) OR .25/.707	0.354 INCHES
ACTUAL WELD LEG (W)	0.432 INCHES

REINFORCEMENT CALCULATION UG-37

AVAILABLE AREA	
SHELL: LARGER OF: (NOTE 1)	E1=1.00
A1A $D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	2.077 IN2
NOZZLE: SMALLER OF:	
5(TN-TRN)(FR2)(T) OR	
A2 5(TN-TRN)(FR2)(TN)	0.350 IN2
ADDITIONAL AREA IF USED (RE-PAD OR INWARD NOZZLE)	
A3 (DP-D-2TN)TE(FR4) OR 2(TN)FR2*H	0.000 IN2
WELD AREA	
A4 W*W*(FR2)	0.175 IN2
ATOT ATOT=A1+A2+A3+A4	2.602 IN2
REQUIRED AREA	
AREQ=D*TR*F+2*TN*TR*F(1-FR1) (F=1.0)	2.244 IN2

REINFORCEMENT CALCULATION APPENDIX (1-7a). (NOTE 2) Rn/R= 0.62

A1(1-7) = LARGER OF A1(1-7)A OR A1(1-7)B	
A1(1-7)A $.5 \cdot D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1(1-7)B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	1.038 IN2
ATOT(1-7)=A1(1-7)+A2+A3+A4	1.563 IN2
AREQ(1-7)=(2/3) X AREQ	1.496 IN2

- (1) E1 NORMALLY EQUALS 1.0. WHEN THE NOZZLE PASSES THROUGH A CATEGORY A WELD JOINT E1 IS TAKEN FROM TABLE UW-12.
- (2) REFERENCE PAR. UG-36(B-1). THIS CALCULATION IS REQUIRED WHEN THE OPENING IS GREATER THAN HALF THE HEADER I.D. OR THE OPENING EXCEEDS 20 INCHES.
- (3) FR1=1.0 OR SN/SV FOR INSERTED NOZZLES.
FR2=SN/SV, FR3=(LESSER OF SN OR SP)/SV, FR4=SP/SV.
- (4) TR & TRN ARE BASED ON SEAMLESS MATERIAL PER DEFINITIONS IN UG-37.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfermark von / Review date:

MAR 29 2005

T.R.

HEADER OPENING AND REINFORCING CALCULATION
PER ASME SECTION VIII, DIV 1., PAR UG-36, UG-40, AND UG-42
(NOZZLE ABUTTS THE HEADER BODY, REF FIG UW-16.1(a))

STREAM	C IN
DESIGN PRESSURE (P)	914. PSIG
HEADER SIZE (O.D.)	10.750 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (T)	0.750 INCHES
INSIDE RADIUS (R)	4.625 INCHES
MINIMUM HEADER THICKNESS (UG-27)	
TR=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.390 INCHES
NOZZLE SIZE (O.D.)	4.500 INCHES
MATERIAL	SB-241-5083-0
ALLOWABLE STRESS (S)	10700. PSI
WALL THICKNESS (TN)	0.237 INCHES
INSIDE DIAMETER (D)	4.026 INCHES
INSIDE RADIUS (R)	2.013 INCHES
MINIMUM NOZZLE THICKNESS	
TRN=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.181 INCHES
HEADER/NOZZLE WELD JOINT	
MIN. WELD LEG =SMALLER OF (T), (TN) OR .25/.707	0.237 INCHES
ACTUAL WELD LEG (W)	0.250 INCHES

REINFORCEMENT CALCULATION UG-37

AVAILABLE AREA	
SHELL: LARGER OF: (NOTE 1)	E1=1.00
A1A $D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	1.451 IN2
NOZZLE: SMALLER OF:	
5(TN - TRN)(FR2)(T) OR	
A2 5(TN - TRN)(FR2)(TN)	0.062 IN2
ADDITIONAL AREA IF USED (RE-PAD OR INWARD NOZZLE)	
A3 $(DP - D - 2TN)TE(FR4) \text{ OR } 2(TN)FR2 \cdot H$	0.000 IN2
WELD AREA	
A4 $W \cdot W \cdot (FR2)$	0.059 IN2
ATOT $ATOT = A1 + A2 + A3 + A4$	1.572 IN2
REQUIRED AREA	
$AREQ = D \cdot TR \cdot F + 2 \cdot TN \cdot TR \cdot F(1 - FR1) \quad (F=1.0)$	1.568 IN2

REINFORCEMENT CALCULATION PER APPENDIX 1-7 DOES NOT APPLY

- (1) E1 NORMALLY EQUALS 1.0. WHEN THE NOZZLE PASSES THROUGH A CATEGORY A WELD JOINT E1 IS TAKEN FROM TABLE UW-12.
- (2) REFERENCE PAR. UG-36(B-1). THIS CALCULATION IS REQUIRED WHEN THE OPENING IS GREATER THAN HALF THE HEADER I.D. OR THE OPENING EXCEEDS 20 INCHES.
- (3) $FR1 = 1.0$ OR SN/SV FOR INSERTED NOZZLES.
 $FR2 = SN/SV$, $FR3 = (\text{LESSER OF } SN \text{ OR } SP)/SV$, $FR4 = SP/SV$.
- (4) TR & TRN ARE BASED ON SEAMLESS MATERIAL PER DEFINITIONS IN UG-37.

Zur Hauptzeichnung zugehörig.
Beilage to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005

TR

HEADER OPENING AND REINFORCING CALCULATION
PER ASME SECTION VIII, DIV 1., PAR UG-36, UG-40, AND UG-42
(NOZZLE ABUTTS THE HEADER BODY, REF FIG UW-16.1(a))

STREAM	C OUT
DESIGN PRESSURE (P)	914. PSIG
HEADER SIZE (O.D.)	5.563 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (T)	0.375 INCHES
INSIDE RADIUS (R)	2.407 INCHES
MINIMUM HEADER THICKNESS (UG-27)	
TR=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.203 INCHES
NOZZLE SIZE (O.D.)	3.500 INCHES
MATERIAL	SB-241-5083-0
ALLOWABLE STRESS (S)	10700. PSI
WALL THICKNESS (TN)	0.216 INCHES
INSIDE DIAMETER (D)	3.068 INCHES
INSIDE RADIUS (R)	1.534 INCHES
MINIMUM NOZZLE THICKNESS	
TRN=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.138 INCHES
HEADER/NOZZLE WELD JOINT	
MIN. WELD LEG = SMALLER OF (T), (TN) OR .25/.707	0.216 INCHES
ACTUAL WELD LEG (W)	0.375 INCHES

REINFORCEMENT CALCULATION UG-37

AVAILABLE AREA	
SHELL: LARGER OF: (NOTE 1)	E1=1.00
A1A $D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	0.529 IN2
NOZZLE: SMALLER OF:	
A2 $5(TN - TRN)(FR2)(T)$ OR	
A2 $5(TN - TRN)(FR2)(TN)$	0.079 IN2
ADDITIONAL AREA IF USED (RE-PAD OR INWARD NOZZLE)	
A3 $(DP - D - 2TN)TE(FR4)$ OR $2(TN)FR2 \cdot H$	0.000 IN2
WELD AREA	
A4 $W \cdot W \cdot (FR2)$	0.132 IN2
ATOT $ATOT = A1 + A2 + A3 + A4$	0.740 IN2
REQUIRED AREA	
AREQ $D \cdot TR \cdot F + 2 \cdot TN \cdot TR \cdot F(1 - FR1)$ (F=1.0)	0.622 IN2

REINFORCEMENT CALCULATION APPENDIX (1-7a). (NOTE 2) Rn/R= 0.64

A1(1-7) = LARGER OF A1(1-7)A OR A1(1-7)B	
A1(1-7)A $.5 \cdot D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1(1-7)B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	0.264 IN2
ATOT(1-7) = A1(1-7) + A2 + A3 + A4	0.475 IN2
AREQ(1-7) = (2/3) X AREQ	0.415 IN2

- (1) E1 NORMALLY EQUALS 1.0. WHEN THE NOZZLE PASSES THROUGH A CATEGORY A WELD JOINT E1 IS TAKEN FROM TABLE UW-12.
- (2) REFERENCE PAR. UG-36(B-1). THIS CALCULATION IS REQUIRED WHEN THE OPENING IS GREATER THAN HALF THE HEADER I.D. OR THE OPENING EXCEEDS 20 INCHES.
- (3) FR1=1.0 OR SN/SV FOR INSERTED NOZZLES.
FR2=SN/SV, FR3=(LESSER OF SN OR SP)/SV, FR4=SP/SV.
- (4) TR & TRN ARE BASED ON SEAMLESS MATERIAL PER DEFINITIONS IN UG-37.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005

T-R

HEADER OPENING AND REINFORCING CALCULATION
PER ASME SECTION VIII, DIV 1., PAR UG-36, UG-40, AND UG-42
(NOZZLE ABUTTS THE HEADER BODY, REF FIG UW-16.1(a))

STREAM	D OUT
DESIGN PRESSURE (P)	580. PSIG
HEADER SIZE (O.D.)	10.750 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (T)	0.500 INCHES
INSIDE RADIUS (R)	4.875 INCHES
MINIMUM HEADER THICKNESS (UG-27)	
TR=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.256 INCHES
NOZZLE SIZE (O.D.)	4.500 INCHES
MATERIAL	SB-241-5083-0
ALLOWABLE STRESS (S)	10700. PSI
WALL THICKNESS (TN)	0.237 INCHES
INSIDE DIAMETER (D)	4.026 INCHES
INSIDE RADIUS (R)	2.013 INCHES
MINIMUM NOZZLE THICKNESS	
TRN=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.113 INCHES
HEADER/NOZZLE WELD JOINT	
MIN. WELD LEG =SMALLER OF (T), (TN) OR .25/.707	0.237 INCHES
ACTUAL WELD LEG (W)	0.237 INCHES

REINFORCEMENT CALCULATION UG-37

AVAILABLE AREA	
SHELL: LARGER OF: (NOTE 1)	E1=1.00
A1A $D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	0.983 IN2
NOZZLE: SMALLER OF:	
5(TN-TRN)(FR2)(T) OR	
A2 5(TN-TRN)(FR2)(TN)	0.138 IN2
ADDITIONAL AREA IF USED (RE-PAD OR INWARD NOZZLE)	
A3 $(DP - D - 2TN)TE(FR4) \text{ OR } 2(TN)FR2 \cdot H$	0.000 IN2
WELD AREA	
A4 $W \cdot W \cdot (FR2)$	0.053 IN2
ATOT $ATOT = A1 + A2 + A3 + A4$	1.174 IN2
REQUIRED AREA	
$AREQ = D \cdot TR \cdot F + 2 \cdot TN \cdot TR \cdot F(1 - FR1)$ (F=1.0)	1.030 IN2

REINFORCEMENT CALCULATION PER APPENDIX 1-7 DOES NOT APPLY

- (1) E1 NORMALLY EQUALS 1.0. WHEN THE NOZZLE PASSES THROUGH A CATEGORY A WELD JOINT E1 IS TAKEN FROM TABLE UW-12.
- (2) REFERENCE PAR. UG-36(B-1). THIS CALCULATION IS REQUIRED WHEN THE OPENING IS GREATER THAN HALF THE HEADER I.D. OR THE OPENING EXCEEDS 20 INCHES.
- (3) FR1=1.0 OR SN/SV FOR INSERTED NOZZLES.
FR2=SN/SV, FR3=(LESSER OF SN OR SP)/SV, FR4=SP/SV.
- (4) TR & TRN ARE BASED ON SEAMLESS MATERIAL PER DEFINITIONS IN UG-37.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005

[Signature]

HEADER OPENING AND REINFORCING CALCULATION
PER ASME SECTION VIII, DIV 1., PAR UG-36,UG-40,AND UG-42
(NOZZLE ABUTTS THE HEADER BODY, REF FIG UW-16.1(a))

STREAM	E OUT
DESIGN PRESSURE (P)	435. PSIG
HEADER SIZE (O.D.)	10.750 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (T)	0.375 INCHES
INSIDE RADIUS (R)	5.000 INCHES
MINIMUM HEADER THICKNESS (UG-27)	
TR=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.195 INCHES
NOZZLE SIZE (O.D.)	3.500 INCHES
MATERIAL	SB-241-5083-0
ALLOWABLE STRESS (S)	10700. PSI
WALL THICKNESS (TN)	0.216 INCHES
INSIDE DIAMETER (D)	3.068 INCHES
INSIDE RADIUS (R)	1.534 INCHES
MINIMUM NOZZLE THICKNESS	
TRN=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.064 INCHES
HEADER/NOZZLE WELD JOINT	
MIN. WELD LEG =SMALLER OF (T), (TN) OR .25/.707	0.216 INCHES
ACTUAL WELD LEG (W)	0.216 INCHES

REINFORCEMENT CALCULATION UG-37

AVAILABLE AREA	
SHELL: LARGER OF: (NOTE 1)	E1=1.00
A1A $D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	0.551 IN2
NOZZLE: SMALLER OF:	
5(TN-TRN)(FR2)(T) OR	
A2 5(TN-TRN)(FR2)(TN)	0.154 IN2
ADDITIONAL AREA IF USED (RE-PAD OR INWARD NOZZLE)	
A3 $(DP - D - 2TN)TE(FR4) \text{ OR } 2(TN)FR2 \cdot H$	0.000 IN2
WELD AREA	
A4 $W \cdot W \cdot (FR2)$	0.044 IN2
ATOT ATOT=A1+A2+A3+A4	0.749 IN2
REQUIRED AREA	
AREQ=D*TR*F+2*TN*TR*F(1-FR1) (F=1.0)	0.599 IN2

REINFORCEMENT CALCULATION PER APPENDIX 1-7 DOES NOT APPLY

- (1) E1 NORMALLY EQUALS 1.0. WHEN THE NOZZLE PASSES THROUGH A CATEGORY A WELD JOINT E1 IS TAKEN FROM TABLE UW-12.
- (2) REFERENCE PAR. UG-36(B-1). THIS CALCULATION IS REQUIRED WHEN THE OPENING IS GREATER THAN HALF THE HEADER I.D. OR THE OPENING EXCEEDS 20 INCHES.
- (3) FR1=1.0 OR SN/SV FOR INSERTED NOZZLES.
FR2=SN/SV, FR3=(LESSER OF SN OR SP)/SV,FR4=SP/SV.
- (4) TR & TRN ARE BASED ON SEAMLESS MATERIAL PER DEFINITIONS IN UG-37.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005

T.R.

HEADER OPENING AND REINFORCING CALCULATION
PER ASME SECTION VIII, DIV 1., PAR UG-36,UG-40,AND UG-42
(NOZZLE ABUTTS THE HEADER BODY, REF FIG UW-16.1(a))

STREAM	F IN
DESIGN PRESSURE (P)	40. PSIG
HEADER SIZE (O.D.)	10.750 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (T)	0.250 INCHES
INSIDE RADIUS (R)	5.125 INCHES
MINIMUM HEADER THICKNESS (UG-27)	
TR=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.018 INCHES
NOZZLE SIZE (O.D.)	10.750 INCHES
MATERIAL	SB-241-5083-0
ALLOWABLE STRESS (S)	10700. PSI
WALL THICKNESS (TN)	0.365 INCHES
INSIDE DIAMETER (D)	10.020 INCHES
INSIDE RADIUS (R)	5.010 INCHES
MINIMUM NOZZLE THICKNESS	
TRN=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.019 INCHES
HEADER/NOZZLE WELD JOINT	
MIN. WELD LEG =SMALLER OF (T),(TN) OR .25/.707	0.250 INCHES
ACTUAL WELD LEG (W)	0.365 INCHES

REINFORCEMENT CALCULATION UG-37

AVAILABLE AREA	
SHELL: LARGER OF: (NOTE 1)	E1=1.00
A1A $D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	2.324 IN2
NOZZLE: SMALLER OF:	
A2 $5(TN - TRN)(FR2)(T)$ OR	
$5(TN - TRN)(FR2)(TN)$	0.406 IN2
ADDITIONAL AREA IF USED (RE-PAD OR INWARD NOZZLE)	
A3 $(DP - D - 2TN)TE(FR4)$ OR $2(TN)FR2 \cdot H$	0.000 IN2
WELD AREA	
A4 $W \cdot W \cdot (FR2)$	0.125 IN2
ATOT $ATOT = A1 + A2 + A3 + A4$	2.856 IN2
REQUIRED AREA	
$AREQ = D \cdot TR \cdot F + 2 \cdot TN \cdot TR \cdot F(1 - FR1)$ (F=1.0)	0.181 IN2

REINFORCEMENT CALCULATION APPENDIX (1-7a). (NOTE 2) $Rn/R = 0.98$

A1(1-7) = LARGER OF A1(1-7)A OR A1(1-7)B	
A1(1-7)A $.5 \cdot D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1(1-7)B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	1.162 IN2
ATOT(1-7) = A1(1-7) + A2 + A3 + A4	1.693 IN2
AREQ(1-7) = (2/3) X AREQ	0.120 IN2

- (1) E1 NORMALLY EQUALS 1.0. WHEN THE NOZZLE PASSES THROUGH A CATEGORY A WELD JOINT E1 IS TAKEN FROM TABLE UW-12.
- (2) REFERENCE PAR. UG-36(B-1). THIS CALCULATION IS REQUIRED WHEN THE OPENING IS GREATER THAN HALF THE HEADER I.D. OR THE OPENING EXCEEDS 20 INCHES.
- (3) $FR1 = 1.0$ OR SN/SV FOR INSERTED NOZZLES.
 $FR2 = SN/SV$, $FR3 = (\text{LESSER OF } SN \text{ OR } SP)/SV$, $FR4 = SP/SV$.
- (4) TR & TRN ARE BASED ON SEAMLESS MATERIAL PER DEFINITIONS IN UG-37.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Printed on 28-Jan-05 date:

MAR 29 2005

T.R.

HEADER OPENING AND REINFORCING CALCULATION
PER ASME SECTION VIII, DIV 1., PAR UG-36,UG-40,AND UG-42
(NOZZLE ABUTTS THE HEADER BODY, REF FIG UW-16.1(a))

STREAM	F OUT
DESIGN PRESSURE (P)	40. PSIG
HEADER SIZE (O.D.)	14.000 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (T)	0.250 INCHES
INSIDE RADIUS (R)	6.750 INCHES
MINIMUM HEADER THICKNESS (UG-27)	
TR=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.024 INCHES
NOZZLE SIZE (O.D.)	12.750 INCHES
MATERIAL	SB-241-5083-0
ALLOWABLE STRESS (S)	10700. PSI
WALL THICKNESS (TN)	0.375 INCHES
INSIDE DIAMETER (D)	12.000 INCHES
INSIDE RADIUS (R)	6.000 INCHES
MINIMUM NOZZLE THICKNESS	
TRN=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.022 INCHES
HEADER/NOZZLE WELD JOINT	
MIN. WELD LEG =SMALLER OF (T), (TN) OR .25/.707	0.250 INCHES
ACTUAL WELD LEG (W)	0.375 INCHES

REINFORCEMENT CALCULATION UG-37

AVAILABLE AREA	
SHELL: LARGER OF: (NOTE 1)	E1=1.00
A1A $D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	2.715 IN2
NOZZLE: SMALLER OF:	
5(TN-TRN)(FR2)(T) OR	
A2 5(TN-TRN)(FR2)(TN)	0.414 IN2
ADDITIONAL AREA IF USED (RE-PAD OR INWARD NOZZLE)	
A3 (DP-D-2TN)TE(FR4) OR 2(TN)FR2*H	0.000 IN2
WELD AREA	
A4 W*W*(FR2)	0.132 IN2
ATOT ATOT=A1+A2+A3+A4	3.261 IN2
REQUIRED AREA	
AREQ=D*TR*F+2*TN*TR*F(1-FR1) (F=1.0)	0.285 IN2


REINFORCEMENT CALCULATION APPENDIX (1-7a). (NOTE 2) Rn/R= 0.89

A1(1-7) = LARGER OF A1(1-7)A OR A1(1-7)B	
A1(1-7)A $.5 \cdot D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1(1-7)B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	1.358 IN2
ATOT(1-7)=A1(1-7)+A2+A3+A4	1.903 IN2
AREQ(1-7)=(2/3) X AREQ	0.190 IN2

- (1) E1 NORMALLY EQUALS 1.0. WHEN THE NOZZLE PASSES THROUGH A CATEGORY A WELD JOINT E1 IS TAKEN FROM TABLE UW-12.
- (2) REFERENCE PAR. UG-36(B-1). THIS CALCULATION IS REQUIRED WHEN THE OPENING IS GREATER THAN HALF THE HEADER I.D. OR THE OPENING EXCEEDS 20 INCHES.
- (3) FR1=1.0 OR SN/SV FOR INSERTED NOZZLES.
FR2=SN/SV, FR3=(LESSER OF SN OR SP)/SV, FR4=SP/SV.
- (4) TR & TRN ARE BASED ON SEAMLESS MATERIAL PER DEFINITIONS IN UG-37.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfungstermin / Review date:

MAR 29 2005



HEADER OPENING AND REINFORCING CALCULATION
PER ASME SECTION VIII, DIV 1., PAR UG-36,UG-40,AND UG-42
(NOZZLE ABUTTS THE HEADER BODY, REF FIG UW-16.1(a))

STREAM	G IN
DESIGN PRESSURE (P)	40. PSIG
HEADER SIZE (O.D.)	14.000 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (T)	0.250 INCHES
INSIDE RADIUS (R)	6.750 INCHES
MINIMUM HEADER THICKNESS (UG-27)	
TR=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.024 INCHES
NOZZLE SIZE (O.D.)	14.000 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (TN)	0.250 INCHES
INSIDE DIAMETER (D)	13.500 INCHES
INSIDE RADIUS (R)	6.750 INCHES
MINIMUM NOZZLE THICKNESS	
TRN=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.024 INCHES
HEADER/NOZZLE WELD JOINT	
MIN. WELD LEG =SMALLER OF (T), (TN) OR .25/.707	0.250 INCHES
ACTUAL WELD LEG (W)	0.250 INCHES

REINFORCEMENT CALCULATION UG-37

AVAILABLE AREA	
SHELL: LARGER OF: (NOTE 1)	E1=1.00
A1A $D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	3.055 IN2
NOZZLE: SMALLER OF:	
5(TN-TRN)(FR2)(T) OR	
A2 5(TN-TRN)(FR2)(TN)	0.283 IN2
ADDITIONAL AREA IF USED (RE-PAD OR INWARD NOZZLE)	
A3 $(DP - D - 2TN)TE(FR4) \text{ OR } 2(TN)FR2 \cdot H$	0.000 IN2
WELD AREA	
A4 $W \cdot W \cdot (FR2)$	0.063 IN2
ATOT $ATOT = A1 + A2 + A3 + A4$	3.400 IN2
REQUIRED AREA	
$AREQ = D \cdot TR \cdot F + 2 \cdot TN \cdot TR \cdot F(1 - FR1) \quad (F=1.0)$	0.320 IN2

REINFORCEMENT CALCULATION APPENDIX (1-7a). (NOTE 2) $R_n/R = 1.00$

A1(1-7) = LARGER OF A1(1-7)A OR A1(1-7)B	
A1(1-7)A $.5 \cdot D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1(1-7)B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	1.527 IN2
ATOT(1-7) = A1(1-7) + A2 + A3 + A4	1.873 IN2
AREQ(1-7) = (2/3) X AREQ	0.214 IN2

- (1) E1 NORMALLY EQUALS 1.0. WHEN THE NOZZLE PASSES THROUGH A CATEGORY A WELD JOINT E1 IS TAKEN FROM TABLE UW-12.
- (2) REFERENCE PAR. UG-36(B-1). THIS CALCULATION IS REQUIRED WHEN THE OPENING IS GREATER THAN HALF THE HEADER I.D. OR THE OPENING EXCEEDS 20 INCHES.
- (3) FR1=1.0 OR SN/SV FOR INSERTED NOZZLES.
FR2=SN/SV, FR3=(LESSER OF SN OR SP)/SV, FR4=SP/SV.
- (4) TR & TRN ARE BASED ON SEAMLESS MATERIAL PER DEFINITIONS IN UG-37.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Approval date:

MAR 29 2005

T.R.

HEADER OPENING AND REINFORCING CALCULATION
PER ASME SECTION VIII, DIV 1., PAR UG-36, UG-40, AND UG-42
(NOZZLE ABUTTS THE HEADER BODY, REF FIG UW-16.1(a))

STREAM	G OUT
DESIGN PRESSURE (P)	40. PSIG
HEADER SIZE (O.D.)	18.000 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (T)	0.250 INCHES
INSIDE RADIUS (R)	8.750 INCHES
MINIMUM HEADER THICKNESS (UG-27)	
TR=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.031 INCHES
NOZZLE SIZE (O.D.)	14.000 INCHES
MATERIAL	SB-209-5083-0
ALLOWABLE STRESS (S)	11400. PSI
WALL THICKNESS (TN)	0.250 INCHES
INSIDE DIAMETER (D)	13.500 INCHES
INSIDE RADIUS (R)	6.750 INCHES
MINIMUM NOZZLE THICKNESS	
TRN=PR/(SE-.6P) (E=1.0 REFERENCE NOTE (4))	0.024 INCHES
HEADER/NOZZLE WELD JOINT	
MIN. WELD LEG =SMALLER OF (T), (TN) OR .25/.707	0.250 INCHES
ACTUAL WELD LEG (W)	0.250 INCHES

REINFORCEMENT CALCULATION UG-37

AVAILABLE AREA	
SHELL: LARGER OF: (NOTE 1)	E1=1.00
A1A $D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	2.960 IN2
NOZZLE: SMALLER OF:	
5(TN - TRN)(FR2)(T) OR	
A2 5(TN - TRN)(FR2)(TN)	0.283 IN2
ADDITIONAL AREA IF USED (RE-PAD OR INWARD NOZZLE)	
A3 $(DP - D - 2TN)TE(FR4)$ OR $2(TN)FR2 \cdot H$	0.000 IN2
WELD AREA	
A4 $W \cdot W \cdot (FR2)$	0.063 IN2
ATOT ATOT=A1+A2+A3+A4	3.305 IN2
REQUIRED AREA	
AREQ=D*TR*F+2*TN*TR*F(1-FR1) (F=1.0)	0.415 IN2

REINFORCEMENT CALCULATION APPENDIX (1-7a). (NOTE 2) Rn/R= 0.77

A1(1-7) = LARGER OF A1(1-7)A OR A1(1-7)B	
A1(1-7)A $.5 \cdot D(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	
A1(1-7)B $2(T + TN)(E1 \cdot T - F \cdot TR) - 2 \cdot TN(E1 \cdot T - F \cdot TR)(1 - FR1)$	1.480 IN2
ATOT(1-7)=A1(1-7)+A2+A3+A4	1.825 IN2
AREQ(1-7)=(2/3) X AREQ	0.277 IN2

- (1) E1 NORMALLY EQUALS 1.0. WHEN THE NOZZLE PASSES THROUGH A CATEGORY A WELD JOINT E1 IS TAKEN FROM TABLE UW-12.
- (2) REFERENCE PAR. UG-36(B-1). THIS CALCULATION IS REQUIRED WHEN THE OPENING IS GREATER THAN HALF THE HEADER I.D. OR THE OPENING EXCEEDS 20 INCHES.
- (3) FR1=1.0 OR SN/SV FOR INSERTED NOZZLES.
FR2=SN/SV, FR3=(LESSER OF SN OR SP)/SV, FR4=SP/SV.
- (4) TR & TRN ARE BASED ON SEAMLESS MATERIAL PER DEFINITIONS IN UG-37.

Zur Hauptzeichnung zugehörig.
Belongs to Main Drawing.
Review date:

MAR 29 2005

T.R.

HEADER AND NOZZLE WALL THICKNESS CALCULATIONS PER APPENDIX 1, PAR. 1-1(a)(1)

NOTE: ALL NOZZLES ARE A MINIMUM OF STD WALL WHICH SATISFIES UG-45(b) REQUIREMENTS OR ARE CHECKED FOR COMPLIANCE WITH UG-45(b)(1).

A IN HEADER 16.000 O.D. X 0.375 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 12.750 O.D. X 0.375 WALL X SB-241-5083-0 SEAMLESS
 DESIGN PRESSURE = 149. PSIG.

$$\begin{aligned} T \text{ REQ. (HEADER)} &= \frac{149. \text{ PSIG} \times 8.000 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 149. \text{ PSIG}} = 0.160 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 0.375 \text{ INCHES} - 0.023 \text{ INCH M.T.} = 0.352 \text{ INCHES}$$

$$\begin{aligned} T \text{ REQ. (NOZZLE)} &= \frac{149. \text{ PSIG} \times 6.375 \text{ INCHES}}{10700. \text{ PSI} \times 1.00 + .4 \times 149. \text{ PSIG}} = 0.088 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.375 \text{ INCHES} \times .875 = 0.328 \text{ INCHES}$$

A OUT HEADER 10.000 O.D. X 0.250 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 8.625 O.D. X 0.322 WALL X SB-241-5083-0 SEAMLESS
 DESIGN PRESSURE = 149. PSIG.

$$\begin{aligned} T \text{ REQ. (HEADER)} &= \frac{149. \text{ PSIG} \times 5.000 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 149. \text{ PSIG}} = 0.100 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 0.250 \text{ INCHES} - 0.018 \text{ INCH M.T.} = 0.232 \text{ INCHES}$$

$$\begin{aligned} T \text{ REQ. (NOZZLE)} &= \frac{149. \text{ PSIG} \times 4.312 \text{ INCHES}}{10700. \text{ PSI} \times 1.00 + .4 \times 149. \text{ PSIG}} = 0.060 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.322 \text{ INCHES} \times .875 = 0.282 \text{ INCHES}$$

B IN HEADER 13.000 O.D. X 1.000 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 6.625 O.D. X 0.432 WALL X SB-241-5083-0 SEAMLESS
 DESIGN PRESSURE = 914. PSIG.

$$\begin{aligned} T \text{ REQ. (HEADER)} &= \frac{914. \text{ PSIG} \times 6.500 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 914. \text{ PSIG}} = 0.764 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 1.000 \text{ INCHES} - 0.055 \text{ INCH M.T.} = 0.945 \text{ INCHES}$$

$$\begin{aligned} T \text{ REQ. (NOZZLE)} &= \frac{914. \text{ PSIG} \times 3.312 \text{ INCHES}}{10700. \text{ PSI} \times 1.00 + .4 \times 914. \text{ PSIG}} = 0.274 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.432 \text{ INCHES} \times .875 = 0.378 \text{ INCHES}$$

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005

T. R.

HEADER AND NOZZLE WALL THICKNESS CALCULATIONS PER APPENDIX 1, PAR. 1-1(a)(1)

NOTE: ALL NOZZLES ARE A MINIMUM OF STD WALL WHICH SATISFIES UG-45(b) REQUIREMENTS OR ARE CHECKED FOR COMPLIANCE WITH UG-45(b)(1).

B OUT HEADER 10.750 O.D. X 0.750 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 6.625 O.D. X 0.432 WALL X SB-241-5083-0 SEAMLESS
 DESIGN PRESSURE = 914. PSIG.

$$\begin{aligned} \text{T REQ. (HEADER)} &= \frac{914. \text{ PSIG} \times 5.375 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 914. \text{ PSIG}} = 0.632 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 0.750 \text{ INCHES} - 0.043 \text{ INCH M.T.} = 0.707 \text{ INCHES}$$

$$\begin{aligned} \text{T REQ. (NOZZLE)} &= \frac{914. \text{ PSIG} \times 3.312 \text{ INCHES}}{10700. \text{ PSI} \times 1.00 + .4 \times 914. \text{ PSIG}} = 0.274 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.432 \text{ INCHES} \times .875 = 0.378 \text{ INCHES}$$

C IN HEADER 10.750 O.D. X 0.750 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 4.500 O.D. X 0.237 WALL X SB-241-5083-0 SEAMLESS
 DESIGN PRESSURE = 914. PSIG.

$$\begin{aligned} \text{T REQ. (HEADER)} &= \frac{914. \text{ PSIG} \times 5.375 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 914. \text{ PSIG}} = 0.632 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 0.750 \text{ INCHES} - 0.043 \text{ INCH M.T.} = 0.707 \text{ INCHES}$$

$$\begin{aligned} \text{T REQ. (NOZZLE)} &= \frac{914. \text{ PSIG} \times 2.250 \text{ INCHES}}{10700. \text{ PSI} \times 1.00 + .4 \times 914. \text{ PSIG}} = 0.186 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.237 \text{ INCHES} \times .875 = 0.207 \text{ INCHES}$$

C OUT HEADER 5.563 O.D. X 0.375 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 3.500 O.D. X 0.216 WALL X SB-241-5083-0 SEAMLESS
 DESIGN PRESSURE = 914. PSIG.

$$\begin{aligned} \text{T REQ. (HEADER)} &= \frac{914. \text{ PSIG} \times 2.782 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 914. \text{ PSIG}} = 0.327 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 0.375 \text{ INCHES} - 0.023 \text{ INCH M.T.} = 0.352 \text{ INCHES}$$

$$\begin{aligned} \text{T REQ. (NOZZLE)} &= \frac{914. \text{ PSIG} \times 1.750 \text{ INCHES}}{10700. \text{ PSI} \times 1.00 + .4 \times 914. \text{ PSIG}} = 0.145 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.216 \text{ INCHES} \times .875 = 0.189 \text{ INCHES}$$

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005

D.R.

HEADER AND NOZZLE WALL THICKNESS CALCULATIONS PER APPENDIX 1, PAR. 1-1(a)(1)

NOTE: ALL NOZZLES ARE A MINIMUM OF STD WALL WHICH SATISFIES UG-45(b) REQUIREMENTS OR ARE CHECKED FOR COMPLIANCE WITH UG-45(b)(1).

D IN HEADER 6.625 O.D. X 0.375 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 2.375 O.D. X 0.154 WALL X SB-241-5083-0 SEAMLESS
 DESIGN PRESSURE = 580. PSIG.

$$\begin{aligned} T \text{ REQ. (HEADER)} &= \frac{580. \text{ PSIG} \times 3.312 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 580. \text{ PSIG}} = 0.251 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 0.375 \text{ INCHES} - 0.023 \text{ INCH M.T.} = 0.352 \text{ INCHES}$$

$$\begin{aligned} T \text{ REQ. (NOZZLE)} &= \frac{580. \text{ PSIG} \times 1.188 \text{ INCHES}}{10700. \text{ PSI} \times 1.00 + .4 \times 580. \text{ PSIG}} = 0.063 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.154 \text{ INCHES} \times .875 = 0.135 \text{ INCHES}$$

D OUT HEADER 10.750 O.D. X 0.500 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 4.500 O.D. X 0.237 WALL X SB-241-5083-0 SEAMLESS
 DESIGN PRESSURE = 580. PSIG.

$$\begin{aligned} T \text{ REQ. (HEADER)} &= \frac{580. \text{ PSIG} \times 5.375 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 580. \text{ PSIG}} = 0.408 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 0.500 \text{ INCHES} - 0.032 \text{ INCH M.T.} = 0.468 \text{ INCHES}$$

$$\begin{aligned} T \text{ REQ. (NOZZLE)} &= \frac{580. \text{ PSIG} \times 2.250 \text{ INCHES}}{10700. \text{ PSI} \times 1.00 + .4 \times 580. \text{ PSIG}} = 0.119 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.237 \text{ INCHES} \times .875 = 0.207 \text{ INCHES}$$

E IN HEADER 2.875 O.D. X 0.203 WALL X SB-241-5083-0 WITHOUT BACKING STRIPS
----- NOZZLE 1.900 O.D. X 0.145 WALL X SB-241-5083-0 SEAMLESS
 DESIGN PRESSURE = 435. PSIG.

$$\begin{aligned} T \text{ REQ. (HEADER)} &= \frac{435. \text{ PSIG} \times 1.438 \text{ INCHES}}{10700. \text{ PSI} \times 0.60 + .4 \times 435. \text{ PSIG}} = 0.095 \text{ INCHES} \end{aligned}$$


$$\text{MINIMUM HEADER THICKNESS} = 0.203 \text{ INCHES} \times .875 = 0.178 \text{ INCHES}$$

$$\begin{aligned} T \text{ REQ. (NOZZLE)} &= \frac{435. \text{ PSIG} \times 0.950 \text{ INCHES}}{10700. \text{ PSI} \times 1.00 + .4 \times 435. \text{ PSIG}} = 0.038 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.145 \text{ INCHES} \times .875 = 0.127 \text{ INCHES}$$

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005



HEADER AND NOZZLE WALL THICKNESS CALCULATIONS PER APPENDIX 1, PAR. 1-1(a)(1)

NOTE: ALL NOZZLES ARE A MINIMUM OF STD WALL WHICH SATISFIES UG-45(b) REQUIREMENTS OR ARE CHECKED FOR COMPLIANCE WITH UG-45(b)(1).

E OUT HEADER 10.750 O.D. X 0.375 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 3.500 O.D. X 0.216 WALL X SB-241-5083-0 SEAMLESS
 DESIGN PRESSURE = 435. PSIG.

$$\begin{aligned} T \text{ REQ. (HEADER)} &= \frac{435. \text{ PSIG} \times 5.375 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 435. \text{ PSIG}} = 0.308 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 0.375 \text{ INCHES} - 0.023 \text{ INCH M.T.} = 0.352 \text{ INCHES}$$

$$\begin{aligned} T \text{ REQ. (NOZZLE)} &= \frac{435. \text{ PSIG} \times 1.750 \text{ INCHES}}{10700. \text{ PSI} \times 1.00 + .4 \times 435. \text{ PSIG}} = 0.070 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.216 \text{ INCHES} \times .875 = 0.189 \text{ INCHES}$$

F IN HEADER 10.750 O.D. X 0.250 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 10.750 O.D. X 0.365 WALL X SB-241-5083-0 SEAMLESS
 DESIGN PRESSURE = 40. PSIG.

$$\begin{aligned} T \text{ REQ. (HEADER)} &= \frac{40. \text{ PSIG} \times 5.375 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 40. \text{ PSIG}} = 0.029 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 0.250 \text{ INCHES} - 0.018 \text{ INCH M.T.} = 0.232 \text{ INCHES}$$

$$\begin{aligned} T \text{ REQ. (NOZZLE)} &= \frac{40. \text{ PSIG} \times 5.375 \text{ INCHES}}{10700. \text{ PSI} \times 1.00 + .4 \times 40. \text{ PSIG}} = 0.020 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.365 \text{ INCHES} \times .875 = 0.319 \text{ INCHES}$$

F OUT HEADER 14.000 O.D. X 0.250 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 12.750 O.D. X 0.375 WALL X SB-241-5083-0 SEAMLESS
 DESIGN PRESSURE = 40. PSIG.

$$\begin{aligned} T \text{ REQ. (HEADER)} &= \frac{40. \text{ PSIG} \times 7.000 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 40. \text{ PSIG}} = 0.038 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 0.250 \text{ INCHES} - 0.018 \text{ INCH M.T.} = 0.232 \text{ INCHES}$$

$$\begin{aligned} T \text{ REQ. (NOZZLE)} &= \frac{40. \text{ PSIG} \times 6.375 \text{ INCHES}}{10700. \text{ PSI} \times 1.00 + .4 \times 40. \text{ PSIG}} = 0.024 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.375 \text{ INCHES} \times .875 = 0.328 \text{ INCHES}$$

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005

T.R.

HEADER AND NOZZLE WALL THICKNESS CALCULATIONS PER APPENDIX 1, PAR. 1-1(a)(1)

NOTE: ALL NOZZLES ARE A MINIMUM OF STD WALL WHICH SATISFIES UG-45(b) REQUIREMENTS OR ARE CHECKED FOR COMPLIANCE WITH UG-45(b)(1).

G IN HEADER 14.000 O.D. X 0.250 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 14.000 O.D. X 0.250 WALL X SB-209-5083-0 TYPE (2) BUTT JOINT
 DESIGN PRESSURE = 40. PSIG.

$$\begin{aligned} T \text{ REQ. (HEADER)} &= \frac{40. \text{ PSIG} \times 7.000 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 40. \text{ PSIG}} = 0.038 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 0.250 \text{ INCHES} - 0.018 \text{ INCH M.T.} = 0.232 \text{ INCHES}$$

$$\begin{aligned} T \text{ REQ. (NOZZLE)} &= \frac{40. \text{ PSIG} \times 7.000 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 40. \text{ PSIG}} = 0.038 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.250 \text{ INCHES} - 0.018 \text{ INCH M.T.} = 0.232 \text{ INCHES}$$

UG-45(b)(1) CHECK: 0.232 INCHES > 0.038 INCHES, UG-45(b) CRITERIA MET

G OUT HEADER 18.000 O.D. X 0.250 WALL X SB-209-5083-0 WITH BACKING STRIPS
----- NOZZLE 14.000 O.D. X 0.250 WALL X SB-209-5083-0 TYPE (2) BUTT JOINT
 DESIGN PRESSURE = 40. PSIG.

$$\begin{aligned} T \text{ REQ. (HEADER)} &= \frac{40. \text{ PSIG} \times 9.000 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 40. \text{ PSIG}} = 0.048 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM HEADER THICKNESS} = 0.250 \text{ INCHES} - 0.018 \text{ INCH M.T.} = 0.232 \text{ INCHES}$$

$$\begin{aligned} T \text{ REQ. (NOZZLE)} &= \frac{40. \text{ PSIG} \times 7.000 \text{ INCHES}}{11400. \text{ PSI} \times 0.65 + .4 \times 40. \text{ PSIG}} = 0.038 \text{ INCHES} \end{aligned}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.250 \text{ INCHES} - 0.018 \text{ INCH M.T.} = 0.232 \text{ INCHES}$$

UG-45(b)(1) CHECK: 0.232 INCHES > 0.048 INCHES, UG-45(b) CRITERIA MET

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005

T.R.

ASME REQUIREMENTS FOR ALUMINUM FLAT UNSTAYED DISKS

DISK DESIGN FOR A OUT NOZZLE 8.625 INCH O.D. BY 0.322 INCH WALL

DESIGN PRESSURE = 149. PSIG
OUTSIDE DIAMETER OF PIPE = 8.625 INCHES
WALL THICKNESS OF PIPE = 0.322 INCHES
INSIDE DIAMETER OF PIPE (D) = 7.981 INCHES
PIPE MATERIAL = SB-241-5083-0 ALUMINUM
ALLOWABLE STRESS OF PIPE = 10700. PSI
DISK MATERIAL = SB-209-5083-0 ALUMINUM
ALLOWABLE STRESS OF DISK = 11400. PSI
THE DISK IS WELDED WITH A BACKING RING.

FACTOR FOR HEAD ATTACHMENT (C)=.33 PER FIG UG-34(H)
JOINT EFFICIENCY (E)=1.0 FOR SEAMLESS DISKS

PER UG-34(C) (2), SECTION VIII, DIVISION 1, OF THE ASME CODE:

$$TMIN(1)=D*\text{SQUARE ROOT OF}(CP/SE) = 0.524 \text{ INCHES}$$

PER FIG UW-13.2(C): $TMIN(2)=TP+B$

WHERE:TP=THE SMALLER OF TN OR .25
B=TN FOR DISKS BEVELED AT A 45 DEGREE ANGLE

$$TMIN(2) = 0.572 \text{ INCHES}$$

WHEN A DISK CLOSURE IS USED A CHECK MUST BE MADE ON THE REQUIRED PIPE WALL THICKNESS. TO COMPLY WITH FIG UG-34(H), A NOZZLE THICKNESS OF 1.25(TR) IS REQUIRED.

PER UG-27(C) (1):

$$TR=PR/(SE-.6P)$$

THUS THE MINIMUM REQUIRED NOZZLE THICKNESS IS:

$$TR=1.25PR/(SE-.6P) = 0.070 \text{ INCHES}$$

$$\text{MINIMUM NOZZLE THICKNESS} = 0.322 \text{ INCHES} \times .875 = 0.282 \text{ INCHES}$$

SINCE THE DISK THICKNESS 0.593 IN. (0.625 IN - 0.032 IN M.T.), MEETS OR EXCEEDS TMIN(1) AND TMIN(2) AND THE ACTUAL PIPE WALL THICKNESS EXCEEDS 1.25(TR) THE DESIGN MEETS THE MINIMUM REQUIREMENTS OF THE ASME CODE.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005

T.R.

MINIMUM ASME THICKNESS REQUIREMENTS FOR ALUMINUM FLATENDS:

FLATEND DESIGN FOR A IN HEADER 16.000 INCH O.D. BY 0.375 INCH WALL

TWO SETS OF CRITERIA MUST BE MET WHEN ATTACHING UNSTAYED FLATENDS TO HEADERS.

THE FIRST IS FOUND IN SECTION VIII, PARA. UG-34(C) (3)
WHICH YIELDS THE FORMULA:

$$T = d \cdot \text{SQARE ROOT OF } (ZCP/SE)$$

WHERE:

d = SHORT SPAN OF A FLAT HEAD (THE RADIUS) = 7.625 INCHES
D = LONG SPAN OF A FLAT HEAD (THE DIAMETER) = 15.250 INCHES
C = HEAD ATTACHMENT FACTOR WHICH = .33m PER FIGURE UG-34(E)
m = tr/ts BUT CONSERVATIVELY SET AT 1.0 THUS C = .33
E = JOINT EFFICIENCY FOR CATEGORY A WELDS; THE PLATE IS
SEAMLESS SO E = 1.0
P = DESIGN PRESSURE = 149. PSIG
S = MAXIMUM ALLOWABLE ASME STRESS VALUE (PSI)

FOR SB-209-5083-0 ALUMINUM S = 11400. PSI

$$Z = 3.4 - (2.4 \cdot d/D)$$

$$\text{HENCE } Z = 3.4 - (2.4 \cdot 7.625/15.250) = 2.20$$

THEREFORE, TMIN, BASED ON THE ABOVE CRITERIA IS:

$$T_{\text{MIN}} = d \cdot \text{SQARE ROOT OF } (Z \cdot .33 \cdot P/SE) = 0.743 \text{ INCHES}$$

THE SECOND CRITERIA IS BASED ON FIGURE UG-34(E) WHICH SPECIFIES THE
FLATEND MUST EXTEND BEYOND THE HEADER BY A DISTANCE NO LESS THAN THE
THICKNESS OF THE SHELL (TS). DESIGN PRACTICE IS TO SELECT A NOMINAL
PLATE THICKNESS OF AT LEAST (TS+.125 IN) TO ALLOW SOME INSERTION OF THE
FLATEND INTO THE HEADER BODY.

THEREFORE THE MINIMUM NOMINAL PLATE THICKNESS IS:

$$T(\text{SHELL}) + 0.125 = 0.500 \text{ INCHES}$$

THE MINIMUM FLATEND THICKNESS 0.945 IN. (1.000 IN NOM. - 0.055 IN M.T.)
MEETS OR EXCEEDS TMIN THEREFORE THE DESIGN MEETS THE MINIMUM REQUIREMENTS
OF THE ASME CODE.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005



MINIMUM ASME THICKNESS REQUIREMENTS FOR ALUMINUM FLATENDS:

FLATEND DESIGN FOR A OUT HEADER 10.000 INCH O.D. BY 0.250 INCH WALL

TWO SETS OF CRITERIA MUST BE MET WHEN ATTACHING UNSTAYED FLATENDS TO HEADERS.

THE FIRST IS FOUND IN SECTION VIII, PARA. UG-34(C)(3)
WHICH YIELDS THE FORMULA:

$$T = d \cdot \text{SQARE ROOT OF}(ZCP/SE)$$

WHERE:

d = SHORT SPAN OF A FLAT HEAD (THE RADIUS) = 4.750 INCHES
D = LONG SPAN OF A FLAT HEAD (THE DIAMETER) = 9.500 INCHES
C = HEAD ATTACHMENT FACTOR WHICH = .33m PER FIGURE UG-34(E)
m = tr/ts BUT CONSERVATIVELY SET AT 1.0 THUS C = .33
E = JOINT EFFICIENCY FOR CATEGORY A WELDS; THE PLATE IS
SEAMLESS SO E = 1.0
P = DESIGN PRESSURE = 149. PSIG
S = MAXIMUM ALLOWABLE ASME STRESS VALUE (PSI)

FOR SB-209-5083-0 ALUMINUM S = 11400. PSI

$$Z=3.4-(2.4 \cdot d/D).$$

$$\text{HENCE } Z=3.4-(2.4 \cdot 4.750/9.500)=2.20$$

THEREFORE, TMIN, BASED ON THE ABOVE CRITERIA IS:

$$T_{\text{MIN}} = d \cdot \text{SQARE ROOT OF}(Z \cdot .33 \cdot P/SE) = 0.463 \text{ INCHES}$$

THE SECOND CRITERIA IS BASED ON FIGURE UG-34(E) WHICH SPECIFIES THE
FLATEND MUST EXTEND BEYOND THE HEADER BY A DISTANCE NO LESS THAN THE
THICKNESS OF THE SHELL (TS). DESIGN PRACTICE IS TO SELECT A NOMINAL
PLATE THICKNESS OF AT LEAST (TS+.125 IN) TO ALLOW SOME INSERTION OF THE
FLATEND INTO THE HEADER BODY.

THEREFORE THE MINIMUM NOMINAL PLATE THICKNESS IS:

$$T(\text{SHELL})+0.125 = 0.375 \text{ INCHES}$$

THE MINIMUM FLATEND THICKNESS 0.468 IN. (0.500 IN NOM.- 0.032 IN M.T.)
MEETS OR EXCEEDS TMIN THEREFORE THE DESIGN MEETS THE MINIMUM REQUIREMENTS
OF THE ASME CODE.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk ein / Review date:

MAR 29 2005



MINIMUM ASME THICKNESS REQUIREMENTS FOR ALUMINUM FLATENDS:

FLATEND DESIGN FOR C OUT HEADER 5.563 INCH O.D. BY 0.375 INCH WALL

TWO SETS OF CRITERIA MUST BE MET WHEN ATTACHING UNSTAYED FLATENDS TO HEADERS.

THE FIRST IS FOUND IN SECTION VIII, PARA. UG-34(C)(3)
WHICH YIELDS THE FORMULA:

$$T = d \cdot \text{SQUARE ROOT OF } (ZCP/SE)$$

WHERE:

d = SHORT SPAN OF A FLAT HEAD (THE RADIUS) = 2.407 INCHES
D = LONG SPAN OF A FLAT HEAD (THE DIAMETER) = 4.813 INCHES
C = HEAD ATTACHMENT FACTOR WHICH = .33m PER FIGURE UG-34(E)
m = tr/ts BUT CONSERVATIVELY SET AT 1.0 THUS C = .33
E = JOINT EFFICIENCY FOR CATEGORY A WELDS; THE PLATE IS
SEAMLESS SO E = 1.0
P = DESIGN PRESSURE = 914. PSIG
S = MAXIMUM ALLOWABLE ASME STRESS VALUE (PSI)

FOR SB-209-5083-0 ALUMINUM S = 11400. PSI

$$Z = 3.4 - (2.4 \cdot d/D).$$

$$\text{HENCE } Z = 3.4 - (2.4 \cdot 2.407 / 4.813) = 2.20$$

THEREFORE, TMIN, BASED ON THE ABOVE CRITERIA IS:

$$T_{\text{MIN}} = d \cdot \text{SQUARE ROOT OF } (Z \cdot .33 \cdot P/SE) = 0.581 \text{ INCHES}$$

THE SECOND CRITERIA IS BASED ON FIGURE UG-34(E) WHICH SPECIFIES THE
FLATEND MUST EXTEND BEYOND THE HEADER BY A DISTANCE NO LESS THAN THE
THICKNESS OF THE SHELL (TS). DESIGN PRACTICE IS TO SELECT A NOMINAL
PLATE THICKNESS OF AT LEAST (TS+.125 IN) TO ALLOW SOME INSERTION OF THE
FLATEND INTO THE HEADER BODY.

THEREFORE THE MINIMUM NOMINAL PLATE THICKNESS IS:

$$T(\text{SHELL}) + 0.125 = 0.500 \text{ INCHES}$$

THE MINIMUM FLATEND THICKNESS 0.593 IN. (0.625 IN NOM. - 0.032 IN M.T.)
MEETS OR EXCEEDS TMIN THEREFORE THE DESIGN MEETS THE MINIMUM REQUIREMENTS
OF THE ASME CODE.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005



MINIMUM ASME THICKNESS REQUIREMENTS FOR ALUMINUM FLATENDS:

FLATEND DESIGN FOR D IN HEADER 6.625 INCH O.D. BY 0.375 INCH WALL

TWO SETS OF CRITERIA MUST BE MET WHEN ATTACHING UNSTAYED FLATENDS TO HEADERS.

THE FIRST IS FOUND IN SECTION VIII, PARA. UG-34(C) (3)
WHICH YIELDS THE FORMULA:

$$T = d \cdot \text{SQUARE ROOT OF } (ZCP/SE)$$

WHERE:

d = SHORT SPAN OF A FLAT HEAD (THE RADIUS) = 2.938 INCHES
D = LONG SPAN OF A FLAT HEAD (THE DIAMETER) = 5.875 INCHES
C = HEAD ATTACHMENT FACTOR WHICH = .33m PER FIGURE UG-34(E)
m = t_r/t_s BUT CONSERVATIVELY SET AT 1.0 THUS C = .33
E = JOINT EFFICIENCY FOR CATEGORY A WELDS; THE PLATE IS
SEAMLESS SO E = 1.0
P = DESIGN PRESSURE = 580. PSIG
S = MAXIMUM ALLOWABLE ASME STRESS VALUE (PSI)

FOR SB-209-5083-0 ALUMINUM S = 11400. PSI

$$Z = 3.4 - (2.4 \cdot d/D)$$

$$\text{HENCE } Z = 3.4 - (2.4 \cdot 2.938 / 5.875) = 2.20$$

THEREFORE, TMIN, BASED ON THE ABOVE CRITERIA IS:

$$T_{\text{MIN}} = d \cdot \text{SQUARE ROOT OF } (Z \cdot .33 \cdot P/SE) = 0.565 \text{ INCHES}$$

THE SECOND CRITERIA IS BASED ON FIGURE UG-34(E) WHICH SPECIFIES THE
FLATEND MUST EXTEND BEYOND THE HEADER BY A DISTANCE NO LESS THAN THE
THICKNESS OF THE SHELL (TS). DESIGN PRACTICE IS TO SELECT A NOMINAL
PLATE THICKNESS OF AT LEAST (TS+.125 IN) TO ALLOW SOME INSERTION OF THE
FLATEND INTO THE HEADER BODY.

THEREFORE THE MINIMUM NOMINAL PLATE THICKNESS IS:

$$T(\text{SHELL}) + 0.125 = 0.500 \text{ INCHES}$$

THE MINIMUM FLATEND THICKNESS 0.593 IN. (0.625 IN NOM. - 0.032 IN M.T.)
MEETS OR EXCEEDS TMIN THEREFORE THE DESIGN MEETS THE MINIMUM REQUIREMENTS
OF THE ASME CODE.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005



MINIMUM ASME THICKNESS REQUIREMENTS FOR ALUMINUM FLATENDS:

FLATEND DESIGN FOR D OUT HEADER 10.750 INCH O.D. BY 0.500 INCH WALL

TWO SETS OF CRITERIA MUST BE MET WHEN ATTACHING UNSTAYED FLATENDS TO HEADERS.

THE FIRST IS FOUND IN SECTION VIII, PARA. UG-34(C) (3)
WHICH YIELDS THE FORMULA:

$$T = d \cdot \text{SQUARE ROOT OF } (ZCP/SE)$$

WHERE:

d = SHORT SPAN OF A FLAT HEAD (THE RADIUS) = 4.875 INCHES
D = LONG SPAN OF A FLAT HEAD (THE DIAMETER) = 9.750 INCHES
C = HEAD ATTACHMENT FACTOR WHICH = .33m PER FIGURE UG-34(E)
m = tr/ts BUT CONSERVATIVELY SET AT 1.0 THUS C = .33
E = JOINT EFFICIENCY FOR CATEGORY A WELDS; THE PLATE IS
SEAMLESS SO E = 1.0
P = DESIGN PRESSURE = 580. PSIG
S = MAXIMUM ALLOWABLE ASME STRESS VALUE (PSI)

FOR SB-209-5083-0 ALUMINUM S = 11400. PSI

$$Z = 3.4 - (2.4 \cdot d/D)$$

$$\text{HENCE } Z = 3.4 - (2.4 \cdot 4.875 / 9.750) = 2.20$$

THEREFORE, TMIN, BASED ON THE ABOVE CRITERIA IS:

$$T_{\text{MIN}} = d \cdot \text{SQUARE ROOT OF } (Z \cdot .33 \cdot P/SE) = 0.937 \text{ INCHES}$$

THE SECOND CRITERIA IS BASED ON FIGURE UG-34(E) WHICH SPECIFIES THE
FLATEND MUST EXTEND BEYOND THE HEADER BY A DISTANCE NO LESS THAN THE
THICKNESS OF THE SHELL (TS). DESIGN PRACTICE IS TO SELECT A NOMINAL
PLATE THICKNESS OF AT LEAST (TS+.125 IN) TO ALLOW SOME INSERTION OF THE
FLATEND INTO THE HEADER BODY.

THEREFORE THE MINIMUM NOMINAL PLATE THICKNESS IS:

$$T(\text{SHELL}) + 0.125 = 0.625 \text{ INCHES}$$

THE MINIMUM FLATEND THICKNESS 0.945 IN. (1.000 IN NOM. - 0.055 IN M.T.)
MEETS OR EXCEEDS TMIN THEREFORE THE DESIGN MEETS THE MINIMUM REQUIREMENTS
OF THE ASME CODE.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005



MINIMUM ASME THICKNESS REQUIREMENTS FOR ALUMINUM FLATENDS:

FLATEND DESIGN FOR E IN HEADER 2.875 INCH O.D. BY 0.203 INCH WALL

TWO SETS OF CRITERIA MUST BE MET WHEN ATTACHING UNSTAYED FLATENDS TO HEADERS.

THE FIRST IS FOUND IN SECTION VIII, PARA. UG-34(C) (3)
WHICH YIELDS THE FORMULA:

$$T = d \cdot \text{SQURE ROOT OF}(ZCP/SE)$$

WHERE:

d = SHORT SPAN OF A FLAT HEAD (THE RADIUS) = 1.235 INCHES
D = LONG SPAN OF A FLAT HEAD (THE DIAMETER) = 2.469 INCHES
C = HEAD ATTACHMENT FACTOR WHICH = .33m PER FIGURE UG-34(E)
m = tr/ts BUT CONSERVATIVELY SET AT 1.0 THUS C = .33
E = JOINT EFFICIENCY FOR CATEGORY A WELDS; THE PLATE IS
SEAMLESS SO E = 1.0
P = DESIGN PRESSURE = 435. PSIG
S = MAXIMUM ALLOWABLE ASME STRESS VALUE (PSI)

FOR SB-209-5083-0 ALUMINUM S = 11400. PSI

$$Z=3.4-(2.4 \cdot d/D).$$

$$\text{HENCE } Z=3.4-(2.4 \cdot 1.235/2.469)=2.20$$

THEREFORE, TMIN, BASED ON THE ABOVE CRITERIA IS:

$$T_{\text{MIN}} = d \cdot \text{SQURE ROOT OF}(Z \cdot .33 \cdot P/SE) = 0.205 \text{ INCHES}$$

THE SECOND CRITERIA IS BASED ON FIGURE UG-34(E) WHICH SPECIFIES THE
FLATEND MUST EXTEND BEYOND THE HEADER BY A DISTANCE NO LESS THAN THE
THICKNESS OF THE SHELL (TS). DESIGN PRACTICE IS TO SELECT A NOMINAL
PLATE THICKNESS OF AT LEAST (TS+.125 IN) TO ALLOW SOME INSERTION OF THE
FLATEND INTO THE HEADER BODY.

THEREFORE THE MINIMUM NOMINAL PLATE THICKNESS IS:

$$T(\text{SHELL}) + 0.125 = 0.328 \text{ INCHES}$$

THE MIMIMUM FLATEND THICKNESS 0.352 IN. (0.375 IN NOM.- 0.023 IN M.T.)
MEETS OR EXCEEDS TMIN THEREFORE THE DESIGN MEETS THE MINIMUM REQUIREMENTS
OF THE ASME CODE.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 2 2005

T.R.

MINIMUM ASME THICKNESS REQUIREMENTS FOR ALUMINUM FLATENDS:

FLATEND DESIGN FOR E OUT HEADER 10.750 INCH O.D. BY 0.375 INCH WALL

TWO SETS OF CRITERIA MUST BE MET WHEN ATTACHING UNSTAYED FLATENDS TO HEADERS.

THE FIRST IS FOUND IN SECTION VIII, PARA. UG-34(C) (3)
WHICH YIELDS THE FORMULA:

$$T = d \cdot \text{SQRT OF } (ZCP/SE)$$

WHERE:

d = SHORT SPAN OF A FLAT HEAD (THE RADIUS) = 5.000 INCHES
D = LONG SPAN OF A FLAT HEAD (THE DIAMETER) = 10.000 INCHES
C = HEAD ATTACHMENT FACTOR WHICH = .33m PER FIGURE UG-34(E)
m = tr/ts BUT CONSERVATIVELY SET AT 1.0 THUS C = .33
E = JOINT EFFICIENCY FOR CATEGORY A WELDS; THE PLATE IS
SEAMLESS SO E = 1.0
P = DESIGN PRESSURE = 435. PSIG
S = MAXIMUM ALLOWABLE ASME STRESS VALUE (PSI)

FOR SB-209-5083-0 ALUMINUM S = 11400. PSI

$$Z = 3.4 - (2.4 \cdot d/D)$$

$$\text{HENCE } Z = 3.4 - (2.4 \cdot 5.000/10.000) = 2.20$$

THEREFORE, TMIN, BASED ON THE ABOVE CRITERIA IS:

$$T_{\text{MIN}} = d \cdot \text{SQRT OF } (Z \cdot .33 \cdot P/SE) = 0.832 \text{ INCHES}$$

THE SECOND CRITERIA IS BASED ON FIGURE UG-34(E) WHICH SPECIFIES THE
FLATEND MUST EXTEND BEYOND THE HEADER BY A DISTANCE NO LESS THAN THE
THICKNESS OF THE SHELL (TS). DESIGN PRACTICE IS TO SELECT A NOMINAL
PLATE THICKNESS OF AT LEAST (TS+.125 IN) TO ALLOW SOME INSERTION OF THE
FLATEND INTO THE HEADER BODY.

THEREFORE THE MINIMUM NOMINAL PLATE THICKNESS IS:

$$T(\text{SHELL}) + 0.125 = 0.500 \text{ INCHES}$$

THE MINIMUM FLATEND THICKNESS 0.945 IN. (1.000 IN NOM.- 0.055 IN M.T.)
MEETS OR EXCEEDS TMIN THEREFORE THE DESIGN MEETS THE MINIMUM REQUIREMENTS
OF THE ASME CODE.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005



MINIMUM ASME THICKNESS REQUIREMENTS FOR ALUMINUM FLATENDS:

FLATEND DESIGN FOR F IN HEADER 10.750 INCH O.D. BY 0.250 INCH WALL

TWO SETS OF CRITERIA MUST BE MET WHEN ATTACHING UNSTAYED FLATENDS TO HEADERS.

THE FIRST IS FOUND IN SECTION VIII, PARA. UG-34(C)(3)
WHICH YIELDS THE FORMULA:

$$T = d \cdot \text{SQURE ROOT OF}(ZCP/SE)$$

WHERE:

d = SHORT SPAN OF A FLAT HEAD (THE RADIUS) = 5.125 INCHES
D = LONG SPAN OF A FLAT HEAD (THE DIAMETER) = 10.250 INCHES
C = HEAD ATTACHMENT FACTOR WHICH = .33m PER FIGURE UG-34(E)
m = t_r/t_s BUT CONSERVATIVELY SET AT 1.0 THUS C = .33
E = JOINT EFFICIENCY FOR CATEGORY A WELDS; THE PLATE IS
SEAMLESS SO E = 1.0
P = DESIGN PRESSURE = 40. PSIG
S = MAXIMUM ALLOWABLE ASME STRESS VALUE (PSI)

FOR SB-209-5083-0 ALUMINUM S = 11400. PSI

$$Z = 3.4 - (2.4 \cdot d/D).$$

$$\text{HENCE } Z = 3.4 - (2.4 \cdot 5.125/10.250) = 2.20$$

THEREFORE, TMIN, BASED ON THE ABOVE CRITERIA IS:

$$T_{\text{MIN}} = d \cdot \text{SQURE ROOT OF}(Z \cdot .33 \cdot P/SE) = 0.259 \text{ INCHES}$$

THE SECOND CRITERIA IS BASED ON FIGURE UG-34(E) WHICH SPECIFIES THE
FLATEND MUST EXTEND BEYOND THE HEADER BY A DISTANCE NO LESS THAN THE
THICKNESS OF THE SHELL (TS). DESIGN PRACTICE IS TO SELECT A NOMINAL
PLATE THICKNESS OF AT LEAST (TS+.125 IN) TO ALLOW SOME INSERTION OF THE
FLATEND INTO THE HEADER BODY.


THEREFORE THE MINIMUM NOMINAL PLATE THICKNESS IS:

$$T(\text{SHELL}) + 0.125 = 0.375 \text{ INCHES}$$

THE MINIMUM FLATEND THICKNESS 0.352 IN. (0.375 IN NOM.- 0.023 IN M.T.)
MEETS OR EXCEEDS TMIN THEREFORE THE DESIGN MEETS THE MINIMUM REQUIREMENTS
OF THE ASME CODE.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005



MINIMUM ASME THICKNESS REQUIREMENTS FOR ALUMINUM FLATENDS:

FLATEND DESIGN FOR F OUT HEADER 14.000 INCH O.D. BY 0.250 INCH WALL

TWO SETS OF CRITERIA MUST BE MET WHEN ATTACHING UNSTAYED FLATENDS TO HEADERS.

THE FIRST IS FOUND IN SECTION VIII, PARA. UG-34(C)(3)
WHICH YIELDS THE FORMULA:

$$T = d \cdot \text{SQUARE ROOT OF } (ZCP/SE)$$

WHERE:

d = SHORT SPAN OF A FLAT HEAD (THE RADIUS) = 6.750 INCHES
D = LONG SPAN OF A FLAT HEAD (THE DIAMETER) = 13.500 INCHES
C = HEAD ATTACHMENT FACTOR WHICH = .33m PER FIGURE UG-34(E)
m = tr/ts BUT CONSERVATIVELY SET AT 1.0 THUS C = .33
E = JOINT EFFICIENCY FOR CATEGORY A WELDS; THE PLATE IS
SEAMLESS SO E = 1.0
P = DESIGN PRESSURE = 40. PSIG
S = MAXIMUM ALLOWABLE ASME STRESS VALUE (PSI)

FOR SB-209-5083-0 ALUMINUM S = 11400. PSI

$$Z = 3.4 - (2.4 \cdot d/D)$$

$$\text{HENCE } Z = 3.4 - (2.4 \cdot 6.750/13.500) = 2.20$$

THEREFORE, TMIN, BASED ON THE ABOVE CRITERIA IS:

$$T_{\text{MIN}} = d \cdot \text{SQUARE ROOT OF } (Z \cdot .33 \cdot P/SE) = 0.341 \text{ INCHES}$$

THE SECOND CRITERIA IS BASED ON FIGURE UG-34(E) WHICH SPECIFIES THE
FLATEND MUST EXTEND BEYOND THE HEADER BY A DISTANCE NO LESS THAN THE
THICKNESS OF THE SHELL (TS). DESIGN PRACTICE IS TO SELECT A NOMINAL
PLATE THICKNESS OF AT LEAST (TS+.125 IN) TO ALLOW SOME INSERTION OF THE
FLATEND INTO THE HEADER BODY.

THEREFORE THE MINIMUM NOMINAL PLATE THICKNESS IS:

$$T(\text{SHELL}) + 0.125 = 0.375 \text{ INCHES}$$

THE MINIMUM FLATEND THICKNESS 0.352 IN. (0.375 IN NOM.- 0.023 IN M.T.)
MEETS OR EXCEEDS TMIN THEREFORE THE DESIGN MEETS THE MINIMUM REQUIREMENTS
OF THE ASME CODE.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 28 2005



MINIMUM ASME THICKNESS REQUIREMENTS FOR ALUMINUM FLATENDS:

FLATEND DESIGN FOR G IN HEADER 14.000 INCH O.D. BY 0.250 INCH WALL

TWO SETS OF CRITERIA MUST BE MET WHEN ATTACHING UNSTAYED FLATENDS TO HEADERS.

THE FIRST IS FOUND IN SECTION VIII, PARA. UG-34(C)(3)
WHICH YIELDS THE FORMULA:

$$T = d \cdot \text{SQURE ROOT OF}(ZCP/SE)$$

WHERE:

d = SHORT SPAN OF A FLAT HEAD (THE RADIUS) = 6.750 INCHES
D = LONG SPAN OF A FLAT HEAD (THE DIAMETER) =13.500 INCHES
C = HEAD ATTACHMENT FACTOR WHICH = .33m PER FIGURE UG-34(E)
m = tr/ts BUT CONSERVATIVELY SET AT 1.0 THUS C = .33
E = JOINT EFFICIENCY FOR CATEGORY A WELDS; THE PLATE IS
SEAMLESS SO E = 1.0
P = DESIGN PRESSURE = 40. PSIG
S = MAXIMUM ALLOWABLE ASME STRESS VALUE (PSI)

FOR SB-209-5083-0 ALUMINUM S = 11400. PSI

$$Z=3.4-(2.4 \cdot d/D).$$

$$\text{HENCE } Z=3.4-(2.4 \cdot 6.750/13.500)= 2.20$$

THEREFORE, TMIN, BASED ON THE ABOVE CRITERIA IS:

$$T_{\text{MIN}} = d \cdot \text{SQURE ROOT OF}(Z \cdot .33 \cdot P/SE) = 0.341 \text{ INCHES}$$

THE SECOND CRITERIA IS BASED ON FIGURE UG-34(E) WHICH SPECIFIES THE
FLATEND MUST EXTEND BEYOND THE HEADER BY A DISTANCE NO LESS THAN THE
THICKNESS OF THE SHELL (TS). DESIGN PRACTICE IS TO SELECT A NOMINAL
PLATE THICKNESS OF AT LEAST (TS+.125 IN) TO ALLOW SOME INSERTION OF THE
FLATEND INTO THE HEADER BODY.


THEREFORE THE MINIMUM NOMINAL PLATE THICKNESS IS:

$$T(\text{SHELL}) + 0.125 = 0.375 \text{ INCHES}$$

THE MIMIMUM FLATEND THICKNESS 0.352 IN. (0.375 IN NOM.- 0.023 IN M.T.)
MEETS OR EXCEEDS TMIN THEREFORE THE DESIGN MEETS THE MINIMUM REQUIREMENTS
OF THE ASME CODE.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk / Review date:

MAR 29 2005



MINIMUM ASME THICKNESS REQUIREMENTS FOR ALUMINUM FLATENDS:

FLATEND DESIGN FOR G OUT HEADER 18.000 INCH O.D. BY 0.250 INCH WALL

TWO SETS OF CRITERIA MUST BE MET WHEN ATTACHING UNSTAYED FLATENDS TO HEADERS.

THE FIRST IS FOUND IN SECTION VIII, PARA. UG-34(C)(3)
WHICH YIELDS THE FORMULA:

$$T = d \cdot \text{SQUARE ROOT OF } (ZCP/SE)$$

WHERE:

d = SHORT SPAN OF A FLAT HEAD (THE RADIUS) = 8.750 INCHES
D = LONG SPAN OF A FLAT HEAD (THE DIAMETER) = 17.500 INCHES
C = HEAD ATTACHMENT FACTOR WHICH = .33m PER FIGURE UG-34(E)
m = tr/ts BUT CONSERVATIVELY SET AT 1.0 THUS C = .33
E = JOINT EFFICIENCY FOR CATEGORY A WELDS; THE PLATE IS
SEAMLESS SO E = 1.0
P = DESIGN PRESSURE = 40. PSIG
S = MAXIMUM ALLOWABLE ASME STRESS VALUE (PSI)

FOR SB-209-5083-0 ALUMINUM S = 11400. PSI

$$Z = 3.4 - (2.4 \cdot d/D).$$

$$\text{HENCE } Z = 3.4 - (2.4 \cdot 8.750/17.500) = 2.20$$

THEREFORE, TMIN, BASED ON THE ABOVE CRITERIA IS:

$$T_{\text{MIN}} = d \cdot \text{SQUARE ROOT OF } (Z \cdot .33 \cdot P/SE) = 0.442 \text{ INCHES}$$

THE SECOND CRITERIA IS BASED ON FIGURE UG-34(E) WHICH SPECIFIES THE
FLATEND MUST EXTEND BEYOND THE HEADER BY A DISTANCE NO LESS THAN THE
THICKNESS OF THE SHELL (TS). DESIGN PRACTICE IS TO SELECT A NOMINAL
PLATE THICKNESS OF AT LEAST (TS+.125 IN) TO ALLOW SOME INSERTION OF THE
FLATEND INTO THE HEADER BODY.


THEREFORE THE MINIMUM NOMINAL PLATE THICKNESS IS:

$$T(\text{SHELL}) + 0.125 = 0.375 \text{ INCHES}$$

THE MINIMUM FLATEND THICKNESS 0.468 IN. (0.500 IN NOM.- 0.032 IN M.T.)
MEETS OR EXCEEDS TMIN THEREFORE THE DESIGN MEETS THE MINIMUM REQUIREMENTS
OF THE ASME CODE.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005



Subject: Supplemental ASME submittal calculations per the 2001 Edition, 2003 Addenda of Section VIII, Division 1.

Customer: AL-DEUTSCHLAND
Sales Order: 509.8
Assembly drawing: 15770A REV A
ITEM: W20000

Maximum design temperature 150. F

Test pressure calculation:

Stream	Test Method	CUSTOMER SPECIFIED DESIGN PRESSURE PSIG		CORRECTION Factor	EQUIVALENT DESIGN PRESSURE PSIG		TEST FACTOR	S test/ S design	Test Pressure PSIG
		PSIG			PSIG				
A	PNEU	109.	X	1.50/1.1	= 149.	X	1.10	X 1.000	= 164.
F	PNEU	29.	X	1.50/1.1	= 40.	X	1.10	X 1.000	= 44.
G	PNEU	29.	X	1.50/1.1	= 40.	X	1.10	X 1.000	= 44.

NOTE: CUSTOMER MANDATED PNEU TEST PRESSURE OF 1.50 TIMES THEIR SPECIFIED DESIGN PRESSURE. CALCULATIONS WERE BASED ON AN EQUIVALENT DESIGN PRESSURE TO CORRECT FOR THE ELEVATED PNEUMATIC TEST PRESSURES.

Stream	Test Method	Test Factor	MAWP PSIG	S test/ S design	Test Pressure PSIG	
B	HYDRO	1.50	X 914.	1.000	=	1371.
C	HYDRO	1.50	X 914.	1.000	=	1371.
D	HYDRO	1.50	X 580.	1.000	=	870.
E	HYDRO	1.50	X 435.	1.000	=	653.

Hydro test factors 1.5 and less will not exceed material yield strengths.

Calculations for Core block components:

Parting sheet calculations:

The parting sheet thickness is selected to carry the outward pressure force on the bar columns of the exchanger. The required thickness is a function of the layer heights and pressures. The calculation method is outlined as follows.


Equation:

$$t_{\text{required}} = \frac{\text{outward pressure}}{\# \text{ of layers} \times S_a}$$

Where: S_a is the allowable parting sheet stress.
Outward pressure = sum of the product of the layer heights x layer pressure.

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfermerk vom / Review date:

MAR 29 2005



Section 1 :

Stream A INACT	30. layers, 0.380" high at	0. psig =	0. lb/in
Stream B	18. layers, 0.201" high at	914. psig =	3307. lb/in
Stream D	9. layers, 0.201" high at	580. psig =	1049. lb/in
Stream E	6. layers, 0.201" high at	435. psig =	525. lb/in
Stream F	30. layers, 0.380" high at	40. psig =	456. lb/in
Stream G	36. layers, 0.380" high at	40. psig =	547. lb/in
sum	129. layers		5884. lb/in

$$\text{min sheet} = \frac{5884. \text{ lb/in}}{129. * 3400. \text{ psi}} = 0.013 \text{ in} < 0.055 \text{ in}$$

$$\text{Ave thk} = \frac{(62 \text{ shts} \times .039") + (30 \text{ shts} \times .059") + (36 \text{ shts} \times .079")}{(62 + 30 + 36)} = .055 \text{ in.}$$

Section 2 :

Stream A	30. layers, 0.380" high at	149. psig =	1699. lb/in
Stream B	18. layers, 0.201" high at	914. psig =	3307. lb/in
Stream D	9. layers, 0.201" high at	580. psig =	1049. lb/in
Stream E	6. layers, 0.201" high at	435. psig =	525. lb/in
Stream F	30. layers, 0.380" high at	40. psig =	456. lb/in
Stream G	36. layers, 0.380" high at	40. psig =	547. lb/in
sum	129. layers		7582. lb/in

$$\text{min sheet} = \frac{7582. \text{ lb/in}}{129. * 3400. \text{ psi}} = 0.017 \text{ in} < 0.055 \text{ in}$$

Section 3 :

Stream A	30. layers, 0.380" high at	149. psig =	1699. lb/in
Stream C	18. layers, 0.201" high at	914. psig =	3307. lb/in
Stream D	9. layers, 0.201" high at	580. psig =	1049. lb/in
Stream E	6. layers, 0.201" high at	435. psig =	525. lb/in
Stream F	30. layers, 0.380" high at	40. psig =	456. lb/in
Stream G	36. layers, 0.380" high at	40. psig =	547. lb/in
sum	129. layers		7582. lb/in

$$\text{min sheet} = \frac{7582. \text{ lb/in}}{129. * 3400. \text{ psi}} = 0.017 \text{ in} < 0.055 \text{ in}$$

Section 4 :

Stream A	30. layers, 0.380" high at	149. psig =	1699. lb/in
Stream C INACT	18. layers, 0.201" high at	0. psig =	0. lb/in
Stream D	9. layers, 0.201" high at	580. psig =	1049. lb/in
Stream E INACT	6. layers, 0.201" high at	0. psig =	0. lb/in
Stream F	30. layers, 0.380" high at	40. psig =	456. lb/in
Stream G	36. layers, 0.380" high at	40. psig =	547. lb/in
sum	129. layers		3751. lb/in

$$\text{min sheet} = \frac{3751. \text{ lb/in}}{129. * 3400. \text{ psi}} = 0.009 \text{ in} < 0.055 \text{ in}$$

Zur Hauptzeichnung zugehörig.
Belongs to the Main Drawing.
Prüfvermerk vom / Review date:

MAR 29 2005

TR